



**Planning Department**

**TOWN OF ACTON**  
472 Main Street  
Acton, Massachusetts 01720  
Telephone (978) 929-6631  
Fax (978) 929-6340  
planning@acton-ma.gov

---

**MEMORANDUM**

**To:** Board of Selectmen **Date:** December 14, 2015  
**From:** Kristen Guichard, AICP, Assistant Town Planner *KSG*  
**Subject:** **Site Plan Special Permit Application #11/06/15 - 458**

---

Location: 267 Great Road  
Map/Parcel: E5-13  
Applicant: Acton Management, Inc.  
Owner: SPS-Acton, LLC  
Engineer: George Dimakarakos, P.E. – Stamski and McNary  
Previous Site Plans: #07/03/14 - 451  
Zoning: Limited Business (LB)  
Groundwater Protection Districts Zone 2 and 3

Lot Area & Developable  
Site Area (same): +/- 98,646 square feet (2.265 acres)  
Proposed Net Floor Area: +/- 17,891 square feet  
(+/- 14,708 square feet (proposed 4 single family dwellings)  
(+/- 3,183 square feet (previously permitted office building and associated parking))

Proposed Floor Area  
Ratio (FAR): .184  
Proposed Uses: Combined Business & Dwelling (4 new single family dwelling units)  
**Hearing Date:** 12/21/15  
**Decision Due:** 3/20/16

---

Below are the Planning Department comments. Please review comments from other departments, boards and agencies.

**Overview**

The Site in review is located off Great Road in the Limited Business (LB) Zoning District. The northerly portion of the property is located within the Groundwater Protection Overlay District Zone 2; the remaining area is located within Zone 3. There are 1,086 square feet of wetlands located on the southeasterly portion of the lot.

In 2014, the Board approved a site plan special permit for a 3,183 square foot office building and associated parking lot on the Site. The Applicant now proposes four single-family dwelling units on the Site behind the previously approved office building with a shared driveway off Gabriel Lane. The proposed four single family dwellings and the previously approved office use is classified as

Combined Business and Dwelling under Bylaw Section 3.5.6. This use is allowed by-right but requires a site plan special permit.

1. The plan shows a proposed bituminous concrete sidewalk along the frontage on Great Road and is designed to connect with the existing sidewalk network. This sidewalk will replace the existing sidewalk.
2. The Applicant has proposed an 18-foot wide driveway off Gabriel Lane with 10" cape cod berms. The Fire Department's comments stated that the drive must be 20-feet wide to meet current access code (527 CMR 1.0). Applicant should confirm with the Fire Department that the proposed cape cod berms comply as part of the required width and provide an analysis and evaluation of fire apparatus maneuvers throughout the access roads (527 CMR 18).
3. The Site and proposed uses comply with minimum parking space requirements set forth in the parking schedule and parking maximums set forth in Section 5.4.6.2.
4. Bylaw Section 6.7.6 requires all parking lots/cells with more than 5 spaces and loading areas be bordered on all sides with a minimum of a 10-foot wide perimeter landscaping area. The original site plan for the office building complied with this requirement but the proposed plan eliminates the 10-foot wide perimeter landscaping for the parking lot. Alternatively the Applicant shows a 10-foot wide landscaping to the easterly portion of the proposed shared driveway which is separate from the parking lot. This does not meet the requirements of the bylaw. The Applicant should amend the plans to include the 10-foot wide landscape area around the parking spaces.
5. A portion of the Site is located within the Groundwater Protection District Zone 2 and complies with the minimum 70% open space and maximum 30% impervious coverage.
6. The Site complies with the Dimensional Regulations set forth in the Bylaw for the Limited Business (LB) District and Groundwater Protection District Zone 3.
7. A portion of Unit 1 is located within the 75 foot and 100 foot wetland buffer zone. The Applicant was in front of the Conservation Commission on December 2, 2015; the hearing was continued to January 6, 2015.

### **Recommendations**

The current plans do not comply with the required 10-foot wide landscape area around the existing parking lot and should be amended. This may require adjustments to other aspects of the plan. The Applicant should also confirm driveway width and access compliance with the Fire Department and address the wetland buffer issues with Unit 1 as required by the Conservation Commission. The property could be reconfigured to comply with these regulations by either relocating some of the housing units or changing some of the single family units to duplexes. In all other respects the plan complies with the Zoning Bylaw. As with all site plans the Board should determine if it is consistent with Bylaw Section 10.4.5. If the Board finds the plans are consistent with Section 10.4.5 the Planning Department could draft a decision for the approval of the Site Plan with conditions addressing comments #2, #4 and #7 above.

The Board should note comments submitted by the Design Review Board, the Fire Department and Acton Water District.

cc: Fire Department  
Engineering Department  
Natural Resources Department